

CITY OF CHARLOTTESVILLE

DEPARTMENT OF PUBLIC WORKS
FACILITIES DEVELOPMENT
305 4th St. NW, Charlottesville, VA 22903
Phone (434) 970-3302

ADDENDUM NO. 2 CATEC Electric Panel Replacement (Phase 1) Addendum Date: 10/21/2021

TO ALL BIDDERS

Project: CATEC Electric Panel Replacement (Phase 1)
IFB#: 22-41 CATEC ELECT PNL REP – PHASE 1
IFB Date: October 4, 2021

The following constitutes an addendum to the Contract Documents dated **10/4/2021**. This addendum shall be attached to the Contract Documents and shall be part thereof to the same extent as if it were originally included. The contractor shall be responsible for coordinating these changes as they affect other work in the Contract Documents. Bidders shall acknowledge receipt of this addendum on their bid form. The Contents of this Addendum alter and amend the original drawings and specifications and take precedence over the related items therein.

THERE IS NO CHANGE TO THE TO THE BID OPENING DATE OR TIME BY THIS ADDENDUM.

SECTION 1 – PRE-BID NOTES, CLARIFICATIONS & MODIFICATIONS

ESCROW AGREEMENT	Review – May not be applicable	28-32 of 99
-------------------------	--------------------------------	-------------

The previous addendum (Addendum 1) as stated above stated that the escrow agreement may not be applicable. It has been determined that the escrow agreement **is not required** for this project. The escrow agreement can be disregarded.

SECTION 2 – BID QUESTIONS

There are no bid questions at this time.

SECTION 3 – CHANGES / MODIFICATIONS TO DESIGN

- Revised Drawings and Specifications** – The revised drawing set Drawings & Specifications titled - CATEC ELECT DWG SET – PH 1 REV 10.13.20 **has been modified**. The main switchboard schedule has been revised to accommodate a spare breaker on Space # 1 for a future welding panel. Sheet 1 of 3 of the PANEL SCHEDULES –PHASE 1 (SHEET 1 OF 3) of Revision 1 shall be removed and replaced with the revised sheet. This is a single page revision to the 1st revision of the drawing set and is a separate pdf attachment to this Addendum. This change shall be taken into consideration when submitting a bid for this project.

END OF ADDENDUM 2